



# HAMPTON FIRE/RESCUE

*A Tradition of Service, Courage and Pride*

True North Property Management  
135 Lafayette Rd.  
Hampton N.H. 03862

To whom it may concern,

Per NFPA 1, 13 and 101, The following SHALL apply to any means of egress or stairways defined as an exit enclosure:

- 1.) Storage of any materials beneath stairways or stair landings within an exit enclosure shall be PROHIBITED at all times.
- 2.) Storage of any materials within the means of egress shall be PROHIBITED at all times.
- 3.) Storage of materials beneath stairways or stair landings shall only be allowed when appropriate sprinkler protection is present and the stairway is not a portion of the means of egress or an exit enclosure.

Any comments or questions regarding the above information may be submitted to this office.

Respectfully,

William A. Paine Jr.  
Fire Prevention Officer  
Town of Hampton Fire Rescue  
140 Winnacunnet Rd.  
Hampton N.H. 03842

*140 Winnacunnet Road Hampton, NH 03842*